

A112 Plumbing Interpretations

Interpretation #: **PI-06-001**

Reference #: A112-DI-06-001 [PIR 05-3]

Date Issued: January 24, 2006

Subject: ASME A112.18.3-2002; Section 3, Reference to ASSE 1025

Question: Section 3 of ASME A112.18.3-2002, Performance Requirements for Backflow Protection Devices and Systems in Plumbing Fixture Fittings, references ANSI/ASSE 1025, Performance Requirements for Diverters for Plumbing Faucets With Hose Spray, Anti-Siphon Type, Residential Applications. This reference does not appear anywhere else in the standard. Was this an error?

Reply: Yes. The reference to ANSI/ASSE 1025 will be deleted in the next revision of the standard. The requirements of ANSI/ASSE 1025 do not apply to ASME A112.18.3-2002.

ASME procedures provide for reconsideration of interpretations when or if additional information is available which the inquirer believes might affect the interpretation. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. As stated in the foreword of the code documents, ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device or activity.