

Code Case OMN-6
Alternate Rules for Digital Instruments

Inquiry: What alternative requirements to those specified in OM Code, subparas. ISTB-4.6.1(b)(2) (1990 Edition through the OMb-1992 Addenda), ISTB-4.7.1(b)(2) (OMc-1994 Addenda through OMc-1997 Addenda), and ISTB-3510(b)(2) (1998 Edition through the OMa-2005 Addenda) may be used for digital instruments used in the performance of inservice testing?

Reply: It is the opinion of the Committee that digital instruments may be selected such that the reference value does not exceed 90% of the calibrated range of the instrument.

Applicability: See Applicability Index.