

Record 17-1521

Approval Date: [issued upon approval]

Case A17.1-XXXX

ASME A17.1-2000 and CSA B44-00 through A17.1-2016/CSA B44-16, Requirement 2.11.10.2,
Illumination at Landing Sills

Inquiry: Does this requirement apply to outdoor elevators that are not located inside a building?

Reply: It is the opinion of the Committee that requirement 2.11.10.2 applies regardless of the presence of a building corridor.